



**Building and Safety  
Permit Service Center**

This form must be completed and signed with copies posted in the attic prior to inspection. The original shall be provided to the Building Inspector at final inspection.

Attics with knob-and-tube wiring may not be insulated, unless a certification letter from a licensed electrical contractor is submitted.

Warning signs indicating the presence of knob-and-tube wiring shall be posted in English and Spanish at all accesses to the attic where knob-and-tube wiring is concealed by insulation prior to inspection.

Numbers in parenthesis refer to code sections of the 2016 edition of the California Electrical Code (CEC)

**Building and Safety**  
1947 Center St. 3<sup>rd</sup> floor  
Berkeley, CA 94704  
510-981-7440 TTY 6903  
[buildingandsafety@cityofberkeley.info](mailto:buildingandsafety@cityofberkeley.info)

# KNOB-AND-TUBE WIRING SAFETY REPORT

**Project Information**

Permit #:

Address:

**Owner Information**

Name:

Phone:

Address:

Email:

**Certifying Electrician Information**

Name:

Phone:

Company:

Bus Lic #:

State Lic #:

Lic. Class:

Address:

City, Zip:

Email:

I certify that the existing knob-and-tube wiring is in good condition with no evidence of deterioration and with proper over-current protection and no improper connections or splices.

The knob-and-tube wiring is not in good condition and may not be covered without repair or rewiring.

The knob-and-tube wiring is disconnected and is not live or has been removed.

Certifying Electrician Signature

Date

**Concealed knob-and-tube shall not be used in:** Hollow spaces of walls, ceilings, and attics where such spaces are insulated by loose, rolled, or foamed-in-place insulating material that envelops the conductors. [CEC §394.12(5)]

**Exception:** This article is not intended to prohibit the installation of insulation where knob-and-tube is present, provided the following are complied with:

1. The wiring shall be surveyed by an electrical contractor licensed by the state of California. Certification shall be provided by the electrical contractor that the existing wiring is in good condition with no evidence of deterioration or improper over-current protection and no improper connections or splices. Repairs, alterations or extensions to the electrical system will require permits and inspections by the authority having jurisdiction for the enforcement of this code.
2. The certification form shall be filed with the by the authority having jurisdiction for the enforcement of this code and a copy furnished to the property owner.
3. All accessible areas in the building where insulation has been installed around knob-and-tube and shall be posted by the insulation contractor with a notice, clearly visible, stating that caution is required when entering these areas. The notice shall be printed in both English and Spanish.
4. The insulation shall be noncombustible as defined in Title 24 Part 2, California Building Code.
5. The insulation shall not have any electrical conductive material as part of or supporting the insulation material.
6. Nothing in this exception will prohibit the authority having jurisdiction for the enforcement of this code from requiring permits and inspections for the installations of thermal insulation.

---

Fold here for posting

**WARNING: Knob and Tube Wiring  
Use Caution When Entering Attic**

**AVISO: Cables de Perilla y Tubo  
Tenga Precaución al Entrar al Ático**